
Room control modules zc-room





Product range

Order code	Description	
zc-room-basic	Basic room controller	
zc-room-lite	Lite room controller	
zc-room	Full feature room controller	

Specifications

Supply voltage	230 V ~ 50 Hz	
DALI supply current	235 mA	
Relay rating	Switched live 10 A Unswitched / emergency test contact 6 A	
Terminal capacity	Mains 1 - 4 mm², strip 8 - 9 mm Digital I/O 0.5 - 2.5 mm², strip 5 - 6 mm	
Load per circuit	10 A	
Load per channel	6 A fluorescent and incandescent lighting 3 A compact fluorescent lighting 3 A low energy lighting DALI power supply 16.5 V dc 235 mA	
Operating temperature	0 to 45°C	
Material	PC	
Classification	Class I	

Safety information

- This product must only be installed by a licensed electrician.
- Before commencing installation or servicing turn off and isolate all supply circuits.
- Risk of accidental contact with live parts. Do not energise with product open or disassembled.
- There are no user serviceable parts, attempting to service any part of the product will void the warranty
- DALI is not SELV and as such should be treated as LV.
- As the installer, it is your responsibility to ensure you comply to all relevant building and safety codes. Refer to application standards for the relevant rules.
- When the installation is complete, leave this manual with the building's owner for future reference.
- Each circuit must be protected by a MCB rated at 16 A or less


Dimensions


Mounting options Independently mounted control for surface mounting

Mounting centres 470 / 150 mm

Dimensions 197 / 500 / 57 mm








Installation

Remove the product from the box and inspect it for any damage. If you believe the product to be damaged or otherwise unsound, *do not* install the product. Please pack it back into its box and return it to the place of purchase for replacement.


If the product is satisfactory, proceed with the installation:


- 1 Ensure safety warnings are adhered to.
- 2 Mount the unit as shown in *fig 1* or *fig 2* using the appropriate fasteners (not included).
- **3** Wire terminal I/O and secure using provided cable clamps or M20 cable glands as per the wiring diagram in *fig 3*.
- **4** Connect starter leads to output channels per wiring diagram in *fig 4*. Emergency luminaires requiring a dedicated emergency test contact should be connected to output 7 10.






0519060_V 1.0





Configuration



Sensor delay		Absence / presence	
Α	В	С	D
¥	10 min	Presence	Reserved for later use
U	15 min	Absence	
a	20 min		
A	30 min		

Notice



For more information on compliant software see our website **zencontrol.com**